FOR QUALITY & EXCELLENCE IN HIGHER EDUCATION
Accredited by NAAC

# BANGALORE UNIVERSITY
## DEPARTMENT OF CIVIL ENGINEERING

Phone Off: 080-22961935 / 1946
E-mail: centrans9@gmail.com

JNANA BHARATHI
BANGALORE - 560 056

**BUB/CTE/2014-15/** **Date: 09-03-2015**

**1. TESTING OF FINE AGGREGATES:**

**Sub**: Testing of Fine Aggregates.
{Project*: Improvements of road in low lying area of Bhadrappa layout Handigudda main and cross road in ward No. 08.}

**Ref.**: Letter No. BUB/Testing/2014-15, dated 07-03-2015
Sample supplied to lab by : Assistant Executive Engineer
Kodigehalli Sub-Division
BBMP, Bangalore.
Name of the Contractor/ Agency*: M/s KRIDL, Bangalore.

**TABLE - 1.1 : SIEVE ANALYSIS :**

| IS Sieve Size, mm | Percentage Passing | Specification as Per IS: 383-1970(Reaffirmed 2002) Percentage Passing | | | Remarks |
|---|---|---|---|---|---|
| | | Zone-I | Zone-II | Zone -III | |
| 04.75 | 97.60 | 90-100 | 90-100 | 90-100 | The Sample Conforms to Grading **Zone-II** |
| 02.36 | 84.10 | 60-95 | 75-100 | 85-100 | |
| 01.18 | 69.80 | 30-70 | 55-90 | 75-100 | |
| 600. mic | 53.10 | 15-34 | 35-59 | 60-79 | |
| 300.mic | 24.50 | 5-20 | 8-30 | 12-40 | |
| 150.mic | 2.65 | 0-10 | 0-10 | 0-10 | |

**TABLE 1.2 ;**

| Sl No | Test Conducted | Sample | Results | Requirements as Per IS. Specification IS :383-1970 (Reaffirmed 2002) |
|---|---|---|---|---|
| 1 | Silt Content | 001 | 1.50 % | Not more than 8% |
| 2. | Specific Gravity | ---- | 2.60 | ------- |

*As furnished by Client.
The Results relate only to the items tested.



Verified

G.R. HARISH
Professor
Department of Civil Engineering
Jnana Bharathi Compus
BANGALORE UNIVERSITY.
Bangalore-560 056.

9/3/2015
Dr. MANJESH .L
ME (Civil Engg ). Ph D MISTE.MIRC
Associate Professor
Department of Civil Engineering
Bangalore University Jnanabharathi Campus
BANGALORE- 560 056
e- mail manjeshl@yahoo.com

FOR QUALITY & EXCELLENCE IN HIGHER EDUCATION
Accredited by NAAC

# BANGALORE UNIVERSITY
## DEPARTMENT OF CIVIL ENGINEERING

Phone Off: 080-22961935 / 1946
E-mail: centrans9@gmail.com

JNANA BHARATHI
BANGALORE - 560 056

**BUB/CTE/2014-15/** **Date: 17-03-2015**

## 1. TEST REPORT ON CEMENT:

**Sub:** Testing of 53 Grade Cement Sample (IS 12269-1987).
{Project*: Improvements of road in low lying area of Bhadrappa layout Handigudda main and cross road in ward No. 08.}

**Ref.**: Letter No. BUB/Testing/2014-15, dated 07-03-2015

Sample supplied to lab by : Assistant Executive Engineer
Kodigehalli Sub-Division
BBMP, Bangalore.

Name of the Contractor/ Agency*: M/s KRIDL, Bangalore.

### PHYSICAL TESTS ON CEMENT

Brand* : Birla Super Grade *: 53
Type * : OPC
Date : 09-03-2015 to 16-03-2015

| SL No | Name of Test | Results | Requirements as per |
|---|---|---|---|
| | | Cement Sample | IS 12269-1987 |
| 1 | Initial setting time | **130 min** | Shall not be less than 30 min |
| 2 | Final setting time | **244 min** | Shall not be more than 600 min |
| 3 | Fineness (by dry sieving on IS 90 micron sieve) | **1.63 %** | Not to exceed 10.0% |
| 4 | Soundness test(by Le-Chatelier's method) | **1.34 mm** | Shall not be more than 10 mm |
| 5 | Compressive strength<br>e) 3 days (average of three results)<br>f) 7 days ( average of three results) | **31.48 N/ Sq mm**<br>**41.62 N/Sq mm** | Shall not be less than 27 N/Sqmm<br>Shall not be less than 37N/Sqmm |

*As furnished by Client.
The Results relate only to the items tested.



G.R. HARISH
Professor
Department of Civil Engineering
Jnana Bharathi Compus
BANGALORE UNIVERSITY
Bangalore-560 056.

Dr. MANJESH .L
ME (Civil Engg ). Ph D MISTE.MIRC
Associate Professor
Department of Civil Engineering
Bangalore University Jnanabharathi Campus
BANGALORE- 560 056
e- mail. manjesh6@yahoo.com

FOR QUALITY & EXCELLENCE IN HIGHER EDUCATION
★ ★ ★ ★ ★
Accredited by NAAC

# BANGALORE UNIVERSITY
## DEPARTMENT OF CIVIL ENGINEERING

Phone Off: 080-22961935 / 1946
E-mail: centrans9@gmail.com

JNANA BHARATHI
BANGALORE - 560 056

**BUB/CTE/2014-15/** **Date: 09-03-2015**

**1. TESTING OF COARSE AGGREGATES ( 40 mm):**

**Sub**: Testing of Coarse Aggregates.
{Project*: Improvements of road in low lying area of Bhadrappa layout Handigudda main and cross road in ward No. 08.}

**Ref.**: Letter No. BUB/Testing/2014-15, dated 07-03-2015

Sample supplied to lab by : Assistant Executive Engineer
Kodigehalli Sub-Division
BBMP, Bangalore.

Name of the Contractor/ Agency*: M/s KRIDL, Bangalore.

**Table - 1.1 : SIEVE ANALYSIS** :

| IS Sieve Size, mm | Percentage passing | Requirements as per IS 383-1970 (Reaffirmed on 2002) % Passing | |
|---|---|---|---|
| | 40 mm Sample | *Single size* | *Graded* |
| 40mm | 97.30 | 85-100 | 95 – 100 |
| 20mm | 42.50 | 0 -20 | 30- 70 |
| 10mm | 21.80 | 0 -5 | 10- 35 |
| 4.75mm | Nil | ------ | 0 - 5 |

**TABLE 1 2** :

| SL No | Test conducted | Sample No | Results | **Requirements** as per IS:383-1970 & Test Conforms to IS 2386( Part I to IV) – 1963 ( Reaffirmed on 2002) |
|---|---|---|---|---|
| 1. | Flakiness Index | As above | 14.96 % | Not to exceed 25 % |
| 2. | Crushing value | ----,,---- | 25.21 % | Not to exceed 45 % for concrete other than for wearing surfaces and 30% for concrete for wearing surfaces |

*As furnished by Client.
The Results relate only to the items tested.



G.R. HARISH
Professor
Department of Civil Engineering
Jnana Bharathi Campus
BANGALORE UNIVERSITY
Bangalore-560 056.

9/3/2015
Dr. MANJESH .L
ME (Civil Engg ) Ph D MISTE.MIRC
Associate Professor
Department of Civil Engineering
Bangalore University Jnanabharathi Campus
BANGALORE- 560 056
e- mail manjeshb@yahoo.com

FOR QUALITY & EXCELLENCE IN HIGHER EDUCATION
★ ★ ★ ★ ★
Accredited by NAAC

# BANGALORE UNIVERSITY
## DEPARTMENT OF CIVIL ENGINEERING

Phone Off: 080-22961935 / 1946
E-mail: centrans9@gmail.com

JNANA BHARATHI
BANGALORE - 560 056

**BUB/CTE/2015-16/** **DATE: 22-04-2015**

**1. TEST REPORT ON CEMENT CONCRETE CUBES :**

**Sub**: Testing of Concrete Cubes (28 days Compressive Strength)
{Project*: Improvements of road in low lying area of Bhadrappa layout Handigudda main and cross road in ward No. 08.}

**Ref.**: Letter No. BUB/Testing/2014-15, dated 20-04-2015

Sample supplied to lab by : Assistant Executive Engineer
Kodigehalli Sub-Division
BBMP, Bangalore.

Name of the Contractor/ Agency*: M/s KRIDL, Bangalore.

AE-B

**RESULTS OF COMPRESSIVE STRENGTH ON CEMENT CONCRETE**

**CUBE SPECIMENS**

Dimensions of Specimen : 150 X 150 X 150mm
Grade of Concrete* : $M_{20}$

**TABLE 1.1 :**

| Sl No | Location/ Identification* | Date of Casting* | Date of Testing | Age in Days | C/S Area in $Mm^2$ | Maximum Load in K.N | Compressive Strength ($N/mm^2$) | Avg. Value |
|---|---|---|---|---|---|---|---|---|
| 1 | 001 | 23-03-15 | 20-04-15 | 28 | 22500 | 540 | 24.00 | **23.48** |
| | 002 | " | " | " | " | 520 | 23.11 | |
| | 003 | " | " | " | " | 525 | 23.33 | |

*As Furnished by Client.

The Results relate only to the items tested.

G.R. HARISH
Professor
Department of Civil Engineering
Jnana Bharathi Compus
BANGALORE UNIVERSITY
Bangalore-560 056.



22/04/2015
Dr. MANJESH .L
ME (Civil Engg ). Ph D MISTE.MIRC
Associate Professor
Department of Civil Engineering
Bangalore University Jnanabharathi Campus
BANGALORE- 560 056
e- mail. manjeshl@yahoo.com

FOR QUALITY & EXCELLENCE IN HIGHER EDUCATION
Accredited by NAAC

# BANGALORE UNIVERSITY
## DEPARTMENT OF CIVIL ENGINEERING

Phone Off: 080-22961935 / 1946
E-mail: centrans9@gmail.com

JNANA BHARATHI
BANGALORE - 560 056

**BUB/CTE/2014-15/** **Date: 09-03-2015**

**1. TEST REPORT ON REINFORCEMENT STEEL :**

**Sub**: Testing of Reinforcement Steel of diameter 10mm.
{Project*: Improvements of road in low lying area of Bhadrappa layout Handigudda main and cross road in ward No. 08.}

**Ref.**: Letter No. BUB/Testing/2014-15, dated 07-03-2015

Sample supplied to lab by : Assistant Executive Engineer
Kodigehalli Sub-Division
BBMP, Bangalore.

Name of the Contractor/ Agency*: M/s KRIDL, Bangalore.

**TABLE – 1**

| SL No | Details | For 10 mm | |
|---|---|---|---|
| | | **Test Results** | Req as per IS 1786-2008 |
| 01 | Observed diameter of bar | **10.0 mm** | 10.0 mm |
| 02 | Observed Wt/m Length **Kg/m** | **0.621** | 0.567 |
| 03 | Proof stress/Yield stress, fy , **N/mm$^2$** | **564.0** | 500.0 |
| 04 | Bend/ Re bend Test | **Ok** | --- |
| 05 | Percentage of Elongation, % | **19.20** | 12.00 |
| 06 | Ultimate Tensile Strength **N/mm$^2$** | **648.0** | 545.0 |

*As furnished by Client.
The Results relate only to the items tested.

G.R. HARISH
Professor
Department of Civil Engineering
Jnana Bharathi Campus
BANGALORE UNIVERSITY
Bangalore-560 056.



9/3/2015
Dr. MANJESH .L
ME (Civil Engg ). Ph D MISTE.MIRC
Associate Professor
Department of Civil Engineering
Bangalore University Jnanabharathi Campus
BANGALORE- 560 056
e- mail. manjeshl@yahoo.com

Verified

Phone Off: 080-22961935 / 1946
E-mail: centrans@vsnl.com

# BANGALORE UNIVERSITY
## DEPARTMENT OF CIVIL ENGINEERING

JNANA BHARATHI
BANGALORE - 560 056

FOR QUALITY & EXCELLENCE IN HIGHER EDUCATION
Accredited by NAAC

BUB/CTE/2015-16/

DATE: 23-04-2015

**1. TEST REPORT ON CEMENT CONCRETE CUBES :**

**Sub**: Testing of Concrete Cubes (28 days Compressive Strength)
{Project*: Improvements of road in low lying area of Bhadrappa layout Handigudda main and cross road in ward No. 08.}

**Ref.**: Letter No. BUB/Testing/2014-15, dated 22-04-2015

Sample supplied to lab by : Assistant Executive Engineer
Kodigehalli Sub-Division
BBMP, Bangalore.

Name of the Contractor/ Agency*: M/s KRIDL, Bangalore.

## RESULTS OF COMPRESSIVE STRENGTH ON CEMENT CONCRETE CUBE SPECIMENS

AC-B

Dimensions of Specimen : 150 X 150 X 150mm
Grade of Concrete* : $M_{20}$

**TABLE 1.1 :**

| Sl No | Location/ Identification* | Date of Casting* | Date of Testing | Age in Days | C/S Area in $Mm^2$ | Maximum Load in K.N | Compressive Strength ($N/mm^2$) | Avg. Value |
|---|---|---|---|---|---|---|---|---|
| 1 | 001 | 24-03-15 | 22-04-15 | 29 | 22500 | 510 | 22.66 | **23.03** |
| | 002 | " | " | " | " | 530 | 23.55 | |
| | 003 | " | " | " | " | 515 | 22.88 | |

*As Furnished by Client.

The Results relate only to the items tested.

G.R. HARISH
Professor
Department of Civil Engineering
Jnana Bharathi Compus
BANGALORE UNIVERSITY
Bangalore-560 056.



23/04/2015

Dr. MANJESH .L
ME (Civil Engg ). Ph D MISTE.MIRC
Associate Professor
Department of Civil Engineering
Bangalore University Jnanabharathi Campus
BANGALORE- 560 056
e- mail. manjeshb@yahoo.com

Verified